



Cummins Inc.

Columbus, Indiana 47201

Engine Data Sheet

Basic Engine Model:
QSK23-G3

Engine Critical Parts List:
CPL: 8352

Curve Number:
FR-50011

Date:
16Jan06

G-DRIVE
QSK
1

Displacement : **23.15 litre (1413 in³)**

Bore : **170 mm (6.69 in.)** Stroke : **170 mm (6.69 in.)**

No. of Cylinders : **6**

Aspiration : **Turbocharged and Air to Air Aftercooled**


Engine Speed RPM	Standby Power		Prime Power		Continuous Power	
	kWm	BHP	kWm	BHP	kWm	BHP
1500	768	1030	701	940	537	720
1800	895	1200	809	1085	652	875

Emissions Certification (1800 RPM Only)

"For mobile applications in the U.S. and Canada, this rating may only be sold in accordance with the OEM TPEM provisions of 40 CFR 89.102. For stationary applications in the U.S. (except California), this rating may be sold through 2006 under the NSPS provisions of 40 CFR Part 60."


Engine Performance Data @ 1500 RPM

OUTPUT POWER			FUEL CONSUMPTION			
%	kWm	BHP	kg/ kWm-h	lb/ BHP-h	litre/ hour	U.S. Gal/ hour
STANDBY POWER						
100	768	1030	0.197	0.323	178	46.9
PRIME POWER						
100	701	940	0.195	0.321	161	42.5
75	526	705	0.196	0.322	121	32.0
50	351	470	0.206	0.338	85	22.4
25	175	235	0.223	0.370	46	12.2
CONTINUOUS POWER						
100	537	720	0.198	0.326	125	33.1




Power Derate Curves @ 1500 RPM

Standby / Prime Power



Continuous Power



Operation At Elevated Temperature And Altitude:

For sustained operation above these conditions, derate by an additional 3.4% per 300 m (1000 ft), and 20% per 10° C (18° F).

CONVERSIONS:(litres = U.S. Gal x 3.785) (U.S. Gal = litres x 0.2642)

Data Subject to Change Without Notice

These guidelines have been formulated to ensure proper application of generator drive engines in A.C. generator set installations. **STANDBY POWER RATING:** Applicable for supplying emergency power for the duration of the utility power outage. No overload capability is available for this rating. Under no condition is an engine allowed to operate in parallel with the public utility at the Standby Power rating. This rating should be applied where reliable utility power is available. A Standby rated engine should be sized for a maximum of an 80% average load factor and 200 hours of operation per year. This includes less than 25 hours per year at the Standby Power rating. Standby ratings should never be applied except in true emergency power outages. Negotiated power outages contracted with a utility company are not considered an emergency. **PRIME POWER RATING:** Applicable for supplying electric power in lieu of commercially purchased power. Prime Power applications must be in the form of one of the following two categories: **UNLIMITED TIME RUNNING PRIME POWER:** Prime Power is available for an unlimited number of hours per year in a variable load application. Variable load should not exceed a 70% average of the Prime Power rating during any operating period of 250 hours. The total operating time at 100% Prime Power shall not exceed 500 hours per year. A 10% overload capability is available for a period of 1 hour within a 12-hour period of operation. Total operating time at the 10% overload power shall not exceed 25 hours per year. **LIMITED TIME RUNNING PRIME POWER:** Limited Time Prime Power is available for a limited number of hours in a non-variable load application. It is intended for use in situations where power outages are contracted, such as in utility power curtailment. Engines may be operated in parallel to the public utility up to 750 hours per year at power levels never to exceed the Prime Power rating. The customer should be aware, however, that the life of any engine will be reduced by this constant high load operation. Any operation exceeding 750 hours per year at the Prime Power rating should use the Continuous Power rating. **CONTINUOUS POWER RATING:** Applicable for supplying utility power at a constant 100% load for an unlimited number of hours per year. No overload capability is available for this rating.

Reference AEB 10.47 for determining Electrical Output.

Data shown above represent gross engine performance capabilities obtained and corrected in accordance with ISO-3046 conditions of 100 kPa (29.53 in Hg) barometric pressure [110 m (361 ft) altitude], 25 °C (77 °F) air inlet temperature, and relative humidity of 30% with No. 2 diesel or a fuel corresponding to ASTM D2. Derates shown are based on 15 in H₂O air intake restriction and 2 in Hg exhaust back pressure.

The fuel consumption data is based on No. 2 diesel fuel weight at 0.85 kg/litre (7.1 lbs/U.S. gal). Power output curves are based on the engine operating with fuel system, water pump and lubricating oil pump; not included are battery charging alternator, fan, optional equipment and driven components.

Data Status: Limited Production

Data Tolerance: ± 5%

Chief Engineer:

D.K. Trueblood



Cummins Inc.

Columbus, Indiana 47201

Engine Data Sheet

Basic Engine Model:
QSK23-G3

Engine Critical Parts List:
CPL: 8352

Curve Number:
FR-50011

Date:
16Jan06

G-DRIVE
QSK
2

Displacement : **23.15 litre (1413 in³)**

Bore : **170 mm (6.69 in.)** Stroke : **170 mm (6.69 in.)**

No. of Cylinders : **6**

Aspiration : **Turbocharged and Air to Air Aftercooled**

Engine Speed RPM	Standby Power		Prime Power		Continuous Power	
	kWm	BHP	kWm	BHP	kWm	BHP
1500	768	1030	701	940	537	720
1800	895	1200	809	1085	652	875


Emissions Certification (1800 RPM Only)

"For mobile applications in the U.S. and Canada, this rating may only be sold in accordance with the OEM TPEM provisions of 40 CFR 89.102. For stationary applications in the U.S. (except California), this rating may be sold through 2006 under the NSPS provisions of 40 CFR Part 60."

Engine Performance Data @ 1800 RPM


OUTPUT POWER			FUEL CONSUMPTION			
%	kWm	BHP	kg/ kWm-h	lb/ BHP-h	litre/ hour	U.S. Gal/ hour
STANDBY POWER						
100	895	1200	0.201	0.332	212	56.1
PRIME POWER						
100	809	1085	0.199	0.326	189	49.8
75	607	814	0.195	0.320	139	36.7
50	405	543	0.204	0.336	97	25.7
25	202	271	0.236	0.385	56	14.7
CONTINUOUS POWER						
100	653	875	0.194	0.320	149	39.4

U.S. Gallons / hour




Power Derate Curves @ 1800 RPM

Standby / Prime Power



Continuous Power



Operation At Elevated Temperature And Altitude:

For sustained operation above these conditions, derate by an additional 5.0% per 300 m (1000 ft), and 7% per 10° C (18° F).

CONVERSIONS:(litres = U.S. Gal x 3.785) (U.S. Gal = litres x 0.2642)

Data Subject to Change Without Notice

These guidelines have been formulated to ensure proper application of generator drive engines in A.C. generator set installations. **STANDBY POWER RATING:** Applicable for supplying emergency power for the duration of the utility power outage. No overload capability is available for this rating. Under no condition is an engine allowed to operate in parallel with the public utility at the Standby Power rating. This rating should be applied where reliable utility power is available. A Standby rated engine should be sized for a maximum of an 80% average load factor and 200 hours of operation per year. This includes less than 25 hours per year at the Standby Power rating. Standby ratings should never be applied except in true emergency power outages. Negotiated power outages contracted with a utility company are not considered an emergency. **PRIME POWER RATING:** Applicable for supplying electric power in lieu of commercially purchased power. Prime Power applications must be in the form of one of the following two categories: **UNLIMITED TIME RUNNING PRIME POWER:** Prime Power is available for an unlimited number of hours per year in a variable load application. Variable load should not exceed a 70% average of the Prime Power rating during any operating period of 250 hours. The total operating time at 100% Prime Power shall not exceed 500 hours per year. A 10% overload capability is available for a period of 1 hour within a 12-hour period of operation. Total operating time at the 10% overload power shall not exceed 25 hours per year. **LIMITED TIME RUNNING PRIME POWER:** Limited Time Prime Power is available for a limited number of hours in a non-variable load application. It is intended for use in situations where power outages are contracted, such as in utility power curtailment. Engines may be operated in parallel to the public utility up to 750 hours per year at power levels never to exceed the Prime Power rating. The customer should be aware, however, that the life of any engine will be reduced by this constant high load operation. Any operation exceeding 750 hours per year at the Prime Power rating should use the Continuous Power rating. **CONTINUOUS POWER RATING:** Applicable for supplying utility power at a constant 100% load for an unlimited number of hours per year. No overload capability is available for this rating.

Reference AEB 10.47 for determining Electrical Output.

Data shown above represent gross engine performance capabilities obtained and corrected in accordance with ISO-3046 conditions of 100 kPa (29.53 in Hg) barometric pressure [110 m (361 ft) altitude], 25 °C (77 °F) air inlet temperature, and relative humidity of 30% with No. 2 diesel or a fuel corresponding to ASTM D2. Derates shown are based on 15 in H₂O air intake restriction and 2 in Hg exhaust back pressure.

The fuel consumption data is based on No. 2 diesel fuel weight at 0.85 kg/litre (7.1 lbs/U.S. gal). Power output curves are based on the engine operating with fuel system, water pump and lubricating oil pump; not included are battery charging alternator, fan, optional equipment and driven components.

Data Status: Limited Production

Data Tolerance: ± 5%

Chief Engineer:

D.K. Trueblood

Cummins Inc.

Engine Data Sheet

ENGINE MODEL : **QSK23-G3**

CONFIGURATION NUMBER : D893001GX03

DATA SHEET : LP-50011

DATE : 16Jan06

PERFORMANCE CURVE : FR-50011

INSTALLATION DIAGRAM

• Fan to Flywheel : 3170553

CPL NUMBER

• Engine Critical Parts List : 8352

GENERAL ENGINE DATA

Type	Inline 6-Cylinder Diesel
Aspiration	Turbocharged and Low Temperature Aftercooled
Bore x Stroke	170 x 170 (6.69 x 6.69)
Displacement	23.15 (1413)
Compression Ratio	16.0:1
Dry Weight	
Fan to Flywheel Engine	2755 (6060)
Wet Weight	
Fan to Flywheel Engine	2805 (6170)
Moment of Inertia of Rotating Components	
• with (SAE 0)	11.6 (270)
Center of Gravity from Front Face of Block	725 (28.5)
Center of Gravity Above Crankshaft Centerline	240 (9.5)
Maximum Static Loading at Rear Main Bearing	990 (2160)

ENGINE MOUNTING

Maximum Bending Moment at Rear Face of Block	3205 (2340)
--	-------------

EXHAUST SYSTEM

Maximum Back Pressure	76.2 (3)
-----------------------------	----------

AIR INDUCTION SYSTEM

Maximum Intake Air Restriction:	
• with Dirty Filter Element	635 (25)
• with Clean Filter Element	381 (15)

COOLING SYSTEM

Coolant Capacity — Engine Only	46.5 (12.3)
Minimum Pressure Cap	69 (10)

Jacket Water Circuit Requirements

Maximum Static Head of Coolant Above Engine Crank Centerline	18.3 (60)
Standard Thermostat (Modulating) Range	76.5-90 (170 - 194)
Maximum Top Tank Temperature for Standby . Prime Power	104 - 100 (220 - 212)
Maximum Coolant Friction Head External to the Engine - 1800 RPM	48 (7)
-1500 RPM	34 (5)

Air-to-Air Core Requirements

Maximum Temp. Rise Between Engine Air Intake and Intake Manifold —1500 / 1800 rpm ..	33 (60)
Maximum Air Press. Drop from Turbo Air Outlet to Intake Manifold — 1500 / 1800 rpm—	102 (4)

LUBRICATION SYSTEM

Oil Pressure @ Idle Speed	145 (21)
@ Governed Speed	345 - 448 (50 - 65)
Maximum Oil Temperature	120 (248)
Oil Capacity with OP TBD Oil Pan : Low - High	66 - 95 (17 - 25)
Total System Capacity (With Combo Filters)	74 - 103 (19 - 27)

